

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Pavon Kumar Vasshney
 (Name of Officers with designation) from P.H.E. DWTL MR4 (Rng)
 (Name of Department/ Office) inspected the 4/8/25
 (Name & Address of the school) on NEIL WORLD SCHOOL, MORENA
01/08/25 (date of inspection) and found that
 the NEIL WORLD SCHOOL, MORENA (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of 3/8/26

Signature with Seal: [Signature]

Name

QUALITY MANAGER
NAB DISTRICT WATER TESTING LABORATORY
MORENA (M.P.)

Designation

Name & Address of the Office / Department : [Signature]

[Signature]
PRINCIPAL
NEIL WORLD SCHOOL
T.R. PURAM, MORENA-476001

To NEIL WORLD SCHOOL
T.R. PURAM, A.B. ROAD, MORENA

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

NABI
DISTRICT WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT MORENA

ANALYSIS REPORT							
CUSTOMER NAME :- <u>श्री अनिल बिहारी अकाउन्टर नील वर्मा स्कूल पी.सा. पुष्प मुरैना</u>							
S. No.	Block	Panchayat	Village Name	Location	Sample Qty	Sample Packing	Source
1	मुरैना	नील वर्मा	स्कूल	फिन्टर प्वांट वाटर	1Ltr.	Acceptable / Not acceptable	R.O.
2	-/-	-/-	-/-	टप वाटर	-/-	Acceptable / Not acceptable	बन
3						Acceptable / Not acceptable	
4						Acceptable / Not acceptable	
5						Acceptable / Not acceptable	

PARTICULARS TO BE FILLED IN THE LABORATORY

Date of Receipt :- <u>01/08/2025</u>	Time of Receipt :- <u>1:40 PM</u>
Date of Analysis Started :- <u>01/08/2025</u>	Date of Analysis Completed :- <u>04/08/2025</u>
UID/Sample No. :- <u>P-681 - P-682</u>	

NATURE OF STUDY - CHEMICAL ANALYSIS

No	Characteristics	Test Method		Unit	AS Per BIS - 10500:2012 & Amendment sep.2018 for Drinking water		Results				
					Requirement (Desirable limit)	Permissible limit in the absence of Alternate source	1	2	3	4	5
1	Taste	IS 3025 RA 2017	Part 8	-	Objectionable	Un Objectionable	Unobj.	Unobj.			
2	Odour	IS 3025 RA 2018	Part 5	-	Agreeable	Un Agreeable	Agreeable	Agreeable			
3	Colour in	IS 3025 RA 2019	Part 26	Hazen scale	5	15	0.0	5.0			
4	Iron (Fe)	-	-	Mg/l	0.3	1.0	0.0	0.0			
5	Nitrate (No ₃)	-	-	Mg/l	45.0	45.0	0.0	0.12			
6	Arsenic (As)	-	-	Mg/l	0.01	0.05	0.0	0.0			
7	Fluoride (F)	-	-	Mg/l	1.0	1.5	0.0	0.0			
8	Chloride as Cl	IS 3025 RA 2019	Part 32	Mg/l	250	1000	84.36	168.24			
9	TDS By Meter	APHA 23 nd 2510 B	Edition	Mg/l	500	2000	210	318			
10	Total Alkalinity as Na ₂ CO ₃	IS 3025 RA 2019	Part 23	Mg/l	200	600	275	285			
11	Total Hardness as CaCO ₃	IS 3025 RA 2019	Part 21	Mg/l	200	600	378	384			
12	Calcium Hardness	-	-	Mg/l	-	-	104	102			
13	Magnesium Hardness	-	-	Mg/l	-	-	274	282			
14	Calcium as Ca	IS 3025 RA 2019	Part 40	Mg/l	75	200	41.60	40.00			
15	Magnesium as Mg	IS 3025 RA 2019	Part 46	Mg/l	30	100	65.76	67.68			
16	Residual Chlorine	IS 3025 RA 2019	Part 26	Mg/l	0.2	1.0	0.0	0.0			
17	Sulphate	-	-	Mg/l	200	400	14.72	18.24			
18	Manganese	-	-	Mg/l	0.1	0.3	0.0	0.0			
19	pH	APHA 23 nd 4500-H + B	Edition	pH scale	6.5 to 8.5	6.5 to 8.5	7.24	7.34			
20	Turbidity in	APHA 23 nd 2130 B	Edition	NTU	1.0	5.0	0.2	0.6			
21	Faecal Coliform (TTC) E.Coli	-	-	-	-	-	0.0	0.0			
22	Total Coliform (per 100 ml)	-	-	-	-	-	-	-			
23	Conductivity at 25°C	APHA 23 nd 2510 B	Edition	Micromhos /cm	-	-					

Remark :- उक्त जल नमूने BIS-10500 के अकाउन्टर अपनी निर्धारित सीमा के पाये जाये है।


Quality Manager
 Public Health Engineer Department
 District Water Testing Laboratory
 Morena (M.P.)


Assistant Engineer
 Public Health Engineer Department
 Sub-division Morena (M.P.)